



AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN
CENTRAL LABORATORY
 (An ISO 9001: 2015 Accredited Laboratory)



Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India
 E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

June 24, 2025.

To,
 The Principal,
 DAV International School,
 Plot No. F.P. - 3 & 6, TPS No. 84-B,
 Off Prahladnagar Road, Makarba, Ahmedabad.

Dear Sir,

We have analyzed your water samples collected on Dt. 19-06-2025 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
A. Organoleptic and Physical Parameters				
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	6.7
3	Turbidity, NTU, Max	1	5	0.45
4	Total dissolved solids, mg/l, Max	500	2000	74
B. General Parameters				
1	Total hardness (as CaCO ₃), mg/l, Max	200	600	20
2	Calcium (as Ca), mg/l, Max	75	200	4
3	Magnesium (as Mg), mg/l, Max	30	100	2.44
4	Chloride (as Cl), mg/l, Max	250	1000	20
5	Sulphate (as SO ₄) mg/l, Max	200	400	< 1.0
6	Total alkalinity (as CaCO ₃), mg/l, Max	200	600	30
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
C. Bacteriological Quality of Drinking Water				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable

Remarks:

- The Central Laboratory, AMC, has collected the samples.
- The result contained in this report relate only to the sample material tested.
- The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.

Dr. Hiren C. Mandalia
 Scientist In-Charge

DD S. of. - 11
28/1/25

R. NO. 1116/73



S. of. 2423
27/1/25

Ahmedabad Municipal Corporation

HEALTH DEPARTMENT
SWM

No. 235


Date : 04/02/25

Sanitary Convenience Certificate

A Certificate for Sanitary Convenience is issued to the Manager / Secretary / Organiser
of the ^{School} Talkies / Theatre named D.A.V. International School
Dr. Nivedita Ganguli Situated
at Makarba, Sarkhel Ahmedabad for
the period of 12 months / Days i. e. from 1/1/2025 to 31/12/2025

"Issued Subject to NOC from other Concerned Departments"

Copy to :-


Sanitary Superintendent
South West Zone (AMC)

1. The manager/Secretary/Organiser
2. The Commissioner of Police, Ahmedabad.


Dy. Director (SWM)
Dy. Health Officer (AMC)
Ahmedabad Municipal Corporation

Zone : _____