



AHMEDABAD MUNICIPAL CORPORATION
MAHANAGAR SEVA SADAN
CENTRAL LABORATORY
(An ISO 9001: 2015 Accredited Laboratory)



Lie No QAC/R91/4650

Dudheshwar Water Works Compound, Dudheshwar, Ahmedabad-380 004, Gujarat, India
E-mail: centrallab@ahmedabadcity.gov.in, Phone No-(079) 25631105, 25630438.

January 16, 2024.

To,
The Principal
DAV International School,
Plot No. F.P.-396, T.P. 84/B,
Makaraba, Ahmedabad - 380051.

Dear Sir,


We have analyzed your water sample collected on Dt. 10-01-2024 for the following **Chemical and Bacteriological** parameters. The analysis report is as hereunder.

Sr. No.	Parameter	Requirement (Acceptable Limit)	Permissible Limit in the Absence of Alternate Source	Sample Value
		As per IS-10500-2012		
A. Organoleptic and Physical Parameters				
1	Colour, Hazen units, Max	5	15	0.1
2	pH value	6.5-8.5	No relaxation	7.94
3	Turbidity, NTU, Max	1	5	0.1
4	Total dissolved solids, mg/l, Max	500	2000	264
B. General Parameters				
1	Total hardness (as CaCO ₃), mg/l, Max	200	600	100
2	Calcium (as Ca), mg/l, Max	75	200	24
3	Magnesium (as Mg), mg/l, Max	30	100	9.76
4	Chloride (as Cl), mg/l, Max	250	1000	70
5	Sulphate (as SO ₄) mg/l, Max	200	400	14.5
6	Total alkalinity (as CaCO ₃), mg/l, Max	200	600	80
7	Free residual chlorine, mg/l, Min	0.2	1.0	Nil
C. Bacteriological Quality of Drinking Water				
1	Total Coliform bacteria, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable
2	E. coli, MPN/100 ml.	Shall not be detectable in any 100 ml sample	Shall not be detectable in any 100 ml sample	Not Detectable

Remarks:

1. The Central Laboratory, AMC, has collected the sample.
2. The result contained in this report relate only to the sample material tested.
3. The report is not being reproduce wholly or in part and cannot be used as evidence in the court of law and should not be used in any advertising media without our special permission in writing.

NOTE — It is recommended that the acceptable limit is to be implemented. Values in excess of those mentioned under 'acceptable' render the water not suitable, but still 'permissible limit in the absence of alternate source' in column 4, above which the sources will have to be rejected. May be tolerated in the absence of an alternative source but up to the limits indicated.


Scientist In-Charge
Central Laboratory

P.No. 116/61

AME S.O. 1
9/4/2024



Invest No. 3573
19/3/24

Ahmedabad Municipal Corporation

No. 285

HEALTH DEPARTMENT
SWM

Date: 9/4/2024

Sanitary Convenience Certificate

A Certificate for Sanitary Convenience is used to the Manager / Secretary / Organiser of the Talkies / ^{School} Theatre named "D.A.V International School" Dr. Nivedita Ganguli Situated at makurba, Sarkhej A/Bod for the period of 12 months / Days i. e. from 1/1/2024 to 31/12/2024

"Issued Subject to NOC from other Concerned Departments"

Copy to :- Sanitary Superintendent
South West Zone (AMC)

1. The manager/Secretary of the Theatre/Organiser.
2. The Commissioner of Police, Ahmedabad.

Dy. Director (SWM)
Dy. Health Officer
Ahmedabad Municipal Corporation (AMC)

Zone :